

INVESTIGATION OF ENERGY LOSS IN A TRANSMISSION SUBSTATION USING ONITSHA 330/132KV AS A CASE STUDY

F.O. Enemuoh, T.L. Alumona and C.H. Aliche

^{1,2} nnamdi azikiwe university, awka, anambra state, nigeria.

³ transmission company of nigeria (tcn)

henryfeatal@gmail.com

Abstract— In transmitting power, energy losses both technical and non-technical occur within the substations and should always be monitored. In this paper, energy loss assessment is carried out in detail using Statistical data collected for two months from all substations under Onitsha 330/132KV transmission substation. In all six substations, statistical data were collected; analysed then energy loss and average energy loss for the month of January and February, 2016 were calculated to be -0.03% and 0.14% respectively which was used to determine how efficient and effective Onitsha 330/132kV transmission substation was transmitting and distributing power during the period. Graphs were plotted using MATCAD to show the percentage of energy loss and effect of station service on energy loss for two months. Probable observed problems were pointed out and suggestions were given to reduce losses and to improve system efficiency.

Index Terms—Energy loss, Transmission substation, Transmission loss, MATCAD, Station service

I. INTRODUCTION

Electrical energy is the most important form of energy to modern day lifestyle [1]. Electrical energy can be generated through conventional and non-conventional means at the best and various locations connected through transmission lines. It is transmitted from long distance to load centres at high voltage using transmission lines and stepped down to a medium and low voltage level for distribution and consumers respectively. Total system energy loss indicates how effectively and efficiently a power system is transmitting power to its consumers [2]. Hence it has become one of the indices for key performance in the power industry. Technical losses represent an economic loss for the country and its optimization should be performed from country's perspective, regardless of institutional organisation of the sector and ownership of operating electricity utilities [3]. Most losses are caused by the technical loss as the non-technical loss is negligible in a transmission substation [2]. A transmission substation steps down extra high and high voltage to medium voltage at a very reliable, safe and efficient means. It consists majorly of transformers and switchgears. Transmission losses are losses that occur in transformers, switchgear contacts, transmission lines and reactors. Transmission loss is therefore the difference between the energy received from generating

station and delivered to distribution stations [4]. It is the amount of energy units not accounted for in terms of monetary value. Energy meters are installed on feeders and transformers to monitor the energy consumed by consumers. These energy meters are not the usual prepaid energy meters we use at homes they are called maximum demand energy meters (MD). The energy meter gives real time of energy consumption on feeders and transformers. Therefore, the energy at different feeders and transformers are known and compared within the substation and the energy loss is determined.

A. FORMS OF TRANSMISSION LOSSES

Energy losses in a power system are attributed to various causes at the generating stations, transmission substation and the distribution substation.
$$\text{Transmission loss} = \{\text{Energy received (MWH)} - \text{Energy distributed at the feeders in (MWH)}\} \quad (1.1)$$
 Energy received (MWH) [4]

The various forms of losses are as follows;

- Losses from generating stations
 1. Inappropriate location of billing meters
 2. Generating station auxiliary services supplied from transmission stations
- Losses from transmission station
 1. Transmission line losses due to energy dissipated as heat on conductors.
 2. Transformer losses which comprises of core loss (Eddy current loss and Hysteresis loss, copper loss (I^2R) in the winding of the transformer).
 3. Losses from reactor and other voltage control equipment in form of heat resulting from I^2R loss and noise.
 4. Losses due to loosed termination and high contact resistance at the joints along transmission lines, switchgears, and terminal equipment in transmission substations.
 5. A low power factor in the system would result in large current which will cause I^2R losses to increase.
- Losses from distribution station (Metering)
 1. Feeders without billing meters

2. Malfunctioning of billing meters
3. Feeders with tampered meter
4. Error in reporting energy meter reading
5. Metering error due to mismatch between specification of instrument transformers and meters.

II. HOTSPOT

Hotspot is the term used to describe a loosed contact heating up leading to high resistance on that joint which would be in a form of glow. The event that lead to energy production and these localized areas are popularly known as hot spot or partial discharges in equipment insulation [5]. The high resistance on that joint is as a result of high current on that spot which actually cause energy loss in form of heat.

This occurs often on conductor clamps, isolator contacts etc. and can be avoided by making sure all loosed contacts are properly tighten, frequent maintenance should be carried out on switchgears, avoid kinks on conductors and use of proper and standard size of conductor.

III. TRANSFORMER LOSSES

Transformers are inductive in nature and they consume the power with lagging power factor. As the power factor falls below unity the current in the system increases increasing power loss (I^2R) [6]. But the key input for estimating transformer energy loss is the transformer load that determines the power factor and energy consumed [2]. Attempts can be made to minimize these losses.

Transformer losses are core losses (hysteresis loss and Eddy current loss) and copper loss (I^2R).

A. CORE LOSSES

Taking place in iron/core part comprising of hysteresis losses and eddy current losses in the core considered to be constant irrespective of load.

Hysteresis losses: hysteresis loss is caused by the cyclic reversal of flux in the magnetic circuit and can be reduced by metallurgical control of the steel [7].

Eddy current loss: Eddy loss is caused by eddy currents circulating within the steel induced by the flow of magnetic flux normal to the width of the core, and it can be controlled by reducing the thickness of the steel lamination or by applying a thin insulating coating [7].

Eddy loss can be expressed as follows:

$$W = Kw^2B^2 \text{ watts}$$

(1.2)

Where;

K = constant

w = width of the core lamination material normal to the flux

B = flux density

IV. COPPER LOSSES OR LOAD LOSS

This takes place in the winding part. As a function of load current, can be divided into (I^2R) loss and stray losses. The stray losses are caused by eddy currents that produce stray electromagnetic flux in the windings, core, core clamps, magnetic shield and other parts of the transformer [2].

Stray loss: Leakage inductance is by itself largely lossless, since energy supplied to its magnetic fields is returned to the supply with the next half-cycle. However, any leakage flux that intercepts nearby conductive materials such as the transformer's support structure will give rise to eddy currents and be converted to heat. Mechanical vibration and audible noise transmission In addition to magnetostriction the alternating magnetic field causes fluctuating forces between the primary and secondary windings. This energy incites vibration transmission in interconnected metalwork, thus amplifying audible transformer hum [2].

V. TRANSMISSION SUBSTATION

A transmission substation is the arrangement of transformers and switchgears in other to step down extra high voltage to high voltage and medium voltage or high voltage to medium voltage at a very reliable, efficient and safe means. The principal items are transformers, overhead lines, towers, circuit breakers, disconnect switches(isolators), bus-bars, shunt reactors, shunt capacitors, current and potential transformers, isolators, control and protection equipment[4]. Figure 1 shows a typical single line diagram (SLD) of a 132/33kV transmission substation




Figure 1; Typical single line diagram (SLD) of a 132/33kV transmission substation.

A. ONITSHA 330/132KV TRANSMISSION SUBSTATION

Onitsha 330/132KV transmission substation has a total capacity of 480MVA, 330/132kV power transformer and 220MVA, 132/33kV power transformer. It evacuates the power generated from okpai generating station which has a capacity of 480MW through a 330kV double circuit transmission line. The substation is connected to the grid network through Alaoji 330kV T/L, Asaba 330kV T/L,

Benin (1) 330kV T/L, Benin (2) 330kV T/L and New Haven 330kV T/L. Also it transmits at 132kV to six (6) substations at different locations as shown in Table 1.0; Table 1.0 shows 132kV substations that receives power from Onitsha 330/132kV Transmission Substation.

S/N	SUB-STATION	TOTAL POWER TRANSFORMER CAPACITY(MVA)
1	Awka 132kV Substation	60MVA 132/33KV
2	Agu-Awka 132KV Substation	40MVA 132/33KV
3	Oji-River 132kV Substation	30MVA 132/33KV & 15MVA 132/66KV
4	G.C.M 132kV Substation	60MVA 132/33KV
5	Nsukka 66kV Substation.	15MVA 66/33KV
6	Onitsha 132kV Substation	220MVA 132/33kV

VI. LOSS CALCULATION APPROACH

The energy loss in Onitsha 330/132kV T/S was investigated by collecting metered energy received from generating station, metered energy transmitted to other 132kV transmission substations, metered energy distributed through 33kV feeders and metered energy used as station services within all transmission substations consumed every day.

Station services is the energy consumed within the substation for control room utility, office utility, switchyard lighting, charging DC batteries etc and it is unaccounted for because energy consumed is not paid for.

The energy consumed by each feeder on individual transformers in all the 132kV transmission substation as listed in Table 1.0, receiving power from Onitsha 330/132kV T/S and its energy consumption is compiled on a daily bases for the month of January to February, 2016.

The energy consumed on the transformer is read from the secondary energy meter also the energy consumed on its outgoing feeders is also read from its individual energy meter. Table 1.1 shows the daily summation of the energy in MWhr from each transmission substation and energy loss is calculated.

Total energy loss = (Energy received – Energy distributed) – station services (1.3)

Energy loss (%) = $\frac{\text{Total energy loss}}{\text{Energy received}} \times 100\%$ (1.4)

Energy received

Table 1.1; Daily summation of the energy in MWhr from each transmission substation and energy loss calculated.

STATION	TRANSFORMER	ENERGY Difference (MWhr)	CTR	33KV FDR NAME	ENERGY Difference (MWhr)	CT	33KV FDR SUM ENERGY
ONITSHA 330/132 KV WORK CENTER	TR11 60MVA	0	1200/1	3-3	107.65	400/1	
	TR12	108.8	1200/5	PP1	108.8		108.8
	TR13	661.34	1200/1	UNIT EZEIWEKA			
	MBTR 132/33KV	280.20	600/1	NICCUSS	210.57	200/5	
	MBTR 132/11KV	195.6	1200/1	NNEWI	344.50	800/1	662.72
	MBTR 2. 132/33KV	400.56	1200/1	LUMUNYA	151.38	400/5	278.97
				OBOSI	127.59	400/5	
				NWAZIKI	195.6		195.6
				WOLIWO			
				AWADA 2	81.71	400/5	400.35
AWKA SUB-STATION	TR3 30MVA 132/33KV	309.4	600/1	A/BARRACKS	318.64	800/1	
	TR1 30MVA 132/33KV	193.44	400/1	TR2	121.27	600/1	309.4
AGU-AWKA SUB.	T1 40MVA 132/33KV	161.2	1200/1	TR4	188.13	400/1	
				AGULU	187.87	600/1	197.95
OJI-RIVER SUB-STATION	T10 15MVA 132/66KV	0	300/1	NENI	10.08	400/1	
	T1A 30MVA 132/33KV	260.9	600/1	AGU-AWKA FEEDER	161.2		161.2
GCM SUB-STATION	TR1 60MVA 132/33KV	348.6000	1200/1	NSUKKA KINGSWAY	0	200/1	0
				OJI LOCAL	49.53	300/1	
				W/WORKS	19.87	400/1	
				ACHI	102.92	400/1	260.9
				COCA COLA	1.01000E+00		
NSUKKA SUB-STATION	T1A 7.5MVA 66/33KV	66.00	150/5	UDI	87.57	400/1	
	T1B 7.5MVA 66/33KV	106.90	200/1	GCM TR4 & GOLDEN OIL	36.4000		348.6000
				ATANI	312.20		
				IBAGWA	-165.41	150/1	
ASABA SUB-STATION	TR1 60MVA 132/33KV	614.00		INJECTION S/S	231.4125		66
	TR2 60MVA 132/33KV	0.00		T3	0.00	500/5	
TOTAL		3706.942			3710.030		3710.030
Total Energy Consumed within the Stations					0.663		
Actual Energy Lost					-3.088		
Total Energy lost					-2.424		
Percentage lost					-0.07%		

Source: Onitsha 330/132kV Transmission Substation (PC&M dept.), Transmission Company of Nigeria (TCN).

Table 1.1 shows a typical daily summation template of all energy received, distributed and consumed by all transmission substations. For the purpose of this paper the daily energy consumed by each substation for the month of January to February, 2016 has been summed, extracted, calculated and compiled in Table 1.2 below;

Table 1.2; Shows the Total Energy received and distributed in the month of January and February, 2016 for all 6 transmission substation.

S/N	TRANSMISSION SUBSTATION	ENERGY RECEIVED (MWhr)		ENERGY DISTRIBUTED (MWhr)	
		January	February	January	February
1	Awka 132kV Substation	16,681.61	9463.85	16,869.91	9462.76
2	Agu-Awka 132KV Substation	9880.60	3005.7	9880.6	3005.7
3	Oji-River 132kV Substation	6163.10	5265.20	6138.77	5245.49
4	G.C.M 132kV Substation	14,563.20	14143.60	14,563.20	14143.60
5	Nsukka 66kV Substation.	5457.60	4551.50	5418.59	4551.90
6	Onitsha 132kV Substation	54,077.03	48300.21	52,913.09	48108.59

Table 1.3; shows the total energy received, distributed and station services consumed every day from the six transmission substations for the month of January, 2016.

DATE	ENERGY RECEIVED(MWhr)	TOTAL ENERGY DISTRIBUTED(MWhr)	TOTAL STATION SERVICES	TOTAL ENERGY LOSS	ENERGY LOSS (%)
1/01/16	3706.942	3710.03	0.663	-2.424	-0.07
2/01/16	3507.631	3511.638	0.708	-3.298	-0.09
3/01/16	3262.399	3257.120	0.705	5.984	0.18
4/01/16	3509.806	3513.791	0.70	-3.285	-0.09
5/01/16	3723.206	3725.761	0.665	-1.890	-0.05
6/01/16	3807.768	3812.503	0.653	-4.082	-0.11
7/01/16	3606.251	3607.319	0.674	-0.393	-0.01
8/01/16	4131.933	4122.277	0.709	10.364	0.25
9/01/16	3978.216	3983.319	0.701	-4.402	-0.11
10/01/16	3830.331	3830.189	0.767	0.909	0.02
11/01/16	3997.386	3998.004	0.802	0.185	0.00
12/01/16	3870.298	3872.966	0.806	-1.863	-0.05
13/01/16	4143.974	4147.64	1.282	-2.508	-0.06
14/01/16	4475.342	4477.591	0.884	-1.366	-0.03
15/01/16	4042.954	4043.749	0.796	0.001	0.00
16/01/16	3822.130	3824.278	0.825	-1.322	-0.03
17/01/16	3762.974	3769.704	0.883	-5.847	-0.16
18/01/16	3798.566	3803.653	0.942	-7.145	-0.19
19/01/16	4158.639	4157.680	0.868	1.826	0.04
20/01/16	3166.137	3170.871	0.839	-3.894	-0.12
21/01/16	3629.005	3627.721	0.784	2.067	0.06
22/01/16	3714.984	3714.216	0.856	1.623	0.04
23/01/16	3165.486	3166.958	0.561	-0.910	-0.03
24/01/16	3650.949	3651.616	0.969	0.301	0.01
25/01/16	3582.280	3583.650	0.698	-0.672	-0.02
26/01/16	4059.870	4023.420	0.761	7.411	0.18
27/01/16	3516.150	3532.70	0.826	-15.724	-0.45
28/01/16	3443.830	3438.490	0.738	6.078	0.18
29/01/16	3783.790	3788.810	0.741	-4.279	-0.11
30/01/16	3881.120	3878.610	0.733	3.243	0.08
31/01/16	3772.290	3777.29	0.690	-4.310	-0.11

Table 1.4 shows the total energy received, distributed and station services consumed every day from the six transmission substations for the month of February, 2016.

DATE	ENERGY RECEIVED(MWhr)	TOTAL ENERGY DISTRIBUTED(MWhr)	TOTAL STATION SERVICES	TOTAL ENERGY LOSS	ENERGY LOSS (%)
1/02/16	3789.09	3790.49	0.670	-0.730	-0.02
2/02/16	3954.38	3954.03	0.635	0.985	0.02
3/02/16	3650.05	3638.39	0.611	12.278	0.34
4/02/16	3500.62	3491.204	0.681	10.10	0.29
5/02/16	3980.52	3975.24	0.776	6.056	0.15
6/02/16	3968.02	3968.76	0.754	0.014	0.00
7/02/16	3935.95	3926.69	0.700	9.960	0.25
8/02/16	3799.46	3799.40	0.764	0.824	0.02
9/02/16	3937.15	3926.67	0.709	11.189	0.28
10/02/16	3870.32	3865.93	0.722	5.112	0.13
11/02/16	3209.57	3204.27	0.753	6.053	0.19
12/02/16	3443.830	3438.490	0.738	6.078	0.18
13/02/16	2367.40	2352.87	0.683	15.213	0.64
14/02/16	2958.64	2972.203	0.661	-12.902	-0.04
15/02/16	3040.89	3034.07	0.806	7.629	0.25
16/02/16	3486.47	3484.00	0.803	3.273	0.09
17/02/16	3344.03	3343.58	0.815	1.265	0.04
18/02/16	3559.69	3552.03	0.818	8.478	0.24
19/02/16	3334.43	3336.77	0.775	-1.565	-0.05
20/02/16	3499.72	3495.93	0.771	4.561	0.13
21/02/16	3205.53	3191.29	0.740	14.980	0.47
22/02/16	3317.90	3322.82	0.712	-4.208	-0.13
23/02/16	3628.05	3623.49	0.764	5.321	0.15
24/02/16	3750.87	3751.18	0.786	0.476	0.01
25/02/16	2978.54	2973.45	0.833	5.923	0.20
26/02/16	3037.80	3033.65	0.786	4.936	0.16
27/02/16	3023.29	3022.72	0.749	1.319	0.04
28/02/16	3140.882	3141.25	0.764	0.394	0.01
29/02/16	3515.89	3511.69	0.803	0.803	0.14

Source: Onitsha 330/132kv Transmission Substation (PC&M dept), Transmission Company of Nigeria (TCN).

From table 1.3, the energy loss is calculated thus;

For 1/01/16,

$$\text{Total energy loss} = (3706.942 - 3710.030) + 0.663 = -2.424$$

Therefore,

$$\text{Energy loss (\%)} = \frac{-2.424}{3706.942} \times 100 = -0.07\%$$

$$\text{Average Energy Loss in January (\%)} = \frac{\sum(\text{Energy loss})}{\text{No. of days}} \quad (1.5)$$

$$= \frac{-0.85}{31} = -0.03\%$$

$$\text{Average Energy Loss in February (\%)} = \frac{\sum(\text{Energy loss})}{\text{No. of days}}$$

$$= \frac{4.18}{29} = 0.14\%$$




Figure 2; Daily energy loss (%) for the month of January, 2016 in




Figure 3; Insignificance of station service for January, 2016.




Figure 4: Total Energy loss for February, 2016




Figure 5; Insignificance of station service in energy loss for February, 2016

• 1.5 CONCLUSION

The method used in this paper makes use of data collected from the 1st of January, 2016 to the 29th of February, 2016 from all transformers and feeders. By calculation the factors energy loss were calculated as shown in table 1.5;

Table 1.5: Summary of Energy Data

	JANUARY	FEBRUARY
Maximum Energy Loss (%)	0.25	0.64
Minimum Energy Loss (%)	-0.11	-0.64
Average Energy Loss (%)	-0.03	0.14

Table 1.5 shows the calculated energy data. It summarizes the efficiency of the transmission substation as we have stated in the introduction that total system energy loss is a key indices used to know how efficient and effective power has been distributed in a transmission substation. The above data has shown that Onitsha 330/132kV transmission substation has been transmitting and distributing power efficiently and effectively. We can draw such conclusion on bases that the Transmission Company of Nigeria's energy loss bench mark is 8%. This could only have been achieved through efficient metering system, proper maintenance, quick response to failed equipment, regular annual maintenance on major equipment such as power transformers, circuit breakers, isolators, CVTs, CTs etc. there are draw backs as to why the transmission substation could not perform better and they are attributed to faulty

energy meters, lack of spares and spare parts, unavailability of voltage transformers on associated feeders, ageing of instrument transformers, poor working condition for Engineers. Energy loss as much as possible has to be minimised and this can be achieved through efficient metering system, low equipment down time, proper maintenance of equipment and installation of voltage transformers on each feeder

References

- [1] A. T. B.L. Theraja, A textbook of electrical technology, New Delhi: S. Chand, 2005.
- [2] A. A. Tamizharasi.P, "Analysis of Distribution Transformer losses in Feeder Circuit.," *International Journal of Innovative Research in Advance Engineering*, pp. 2-3, 2014.
- [3] P. Antmann, "Reducing Technical and Non-Technical Losses in the Power Sector," 2009.
- [4] TCN, "Transmission News," *In house journal of Transmission Company of Nigeria. Vol 4*, pp. 59-60, 2015.
- [5] V. R. M. B. M. M. S. Harishkumar, "Detection of hot spots by thermal imaging to protect power equipments," *International Journal of students research in technology & management*, vol. 2, no. 02, pp. 64-66, 2014.
- [6] A. O. T. M. N.A. Uzodife, "Power loss reduction in electrical distribution systems using capacitor placement," *International Journal of Technical Research and Applications*, vol. 3, no. 3, pp. 147-152, 2015.
- [7] J. H. Harlow, *Electric Power Transformer Engineering*, Florida: CRC Press LLC, 2004.
- [8] O. U. O. I. M.S. Okundamiya, "Investigation and Evaluation of Voltage Drops: A Case Study of Guinness and Ikpoba Dam Injection Substations," *International Journal of Electrical and Power Engineering*, vol. 3, no. 2, pp. 105-111, 2009.